

TITLE 7

FIRE PROTECTION AND FIREWORKS

CHAPTER 6

AUTOMATIC SPRINKLERS

SECTION

7-607. Miscellaneous provisions:

7-607. Miscellaneous provisions. (8) A key box may be provided outside the main entrance to any non-residential building regulated hereunder, containing a key to allow access to all fire department areas, except duplexes and multi-family dwellings which shall only provide access to fire sprinkler control valves. If, however, a key box is installed, the device shall be a standard brand and shall be approved by the fire codes official and fire chief for the Town of Smyrna. Key boxes, approved in accordance with this section, may be placed on existing buildings. If a key box is to be installed on an existing building, it shall be installed in accordance with the policy and specifications agreed to by the fire codes enforcement official and the fire chief. The location of the key box shall be standardized and shall be placed as specified by agreement of the fire codes enforcement official and the fire chief. Each key box installation location shall be approved by the fire codes official and fire chief for the town. Access to the key box shall not be blocked. It shall be unlawful and a violation of this chapter to disable, damage, or otherwise tamper with such key boxes.